

CENTRAL POWER RESEARCH INSTITUTE
(Member of STL)



TEST REPORT

CPRI

Test Report No: 2014/STL/121

Date :

21 MAR 2014

SUMMARY OF TEST

1. Test conducted : Degree of Protection IP - 65
2. Rating for which tested : 1) Ingress protection against solid particles IP-6X
2) Ingress protection against liquids IP-X5
3. DOCUMENTS CONSTITUTING THIS REPORT :
 - 3.1 Supplementary test report : NIL
 - 3.2 Oscillogram No(s) : NIL
 - 3.3 Drawing of the equipment tested : DWG/JECPL/CPRI/JB/01 Rev A
 - 3.4 Test circuit drawing No(s). : NIL
 - 3.5 Photograph No(s). : NIL


(PRADEEP JAIN)
TEST ENGINEER

CENTRAL POWER RESEARCH INSTITUTE
(Member of STL)



CPRI

TEST REPORT

Test Report No: 2014/STL/121

Date :

21 MAR 2014

DESCRIPTION OF THE SAMPLE TESTED
(As assigned by the manufacturer)

Sample	:	L.T. Panel
Rated Voltage (Volts)	:	415
Rated current (Amps)	:	630
Frequency (Hz)	:	50
Insulation level (Volts)	:	660
Number of Phases	:	Three + Neutral
Number of Poles	:	-
Contacts/Terminals material	:	-
Dimension of equipment	:	As per drawing


(PRADEEP JAIN)
TEST ENGINEER