CENTRAL POWER RESEARCH INSTITUTE (MEMBER OF STL)





Test Report Number

S2140065

27 FEB 2014

Name & address of the Customer

M/s Jagruti Electro Controls Pvt.Ltd.

45, Gopi Industrial Estate, B/H Ramdev Masala

Ahmedabad.

Name & address of the Manufacturer

M/s Jagruti Electro Controls Pvt.Ltd.

45, Gopi Industrial Estate, B/H Ramdev Masala

Ahmedabad.

Particulars of sample tested Condition of sample on Receipt

LT Panel

Type

New

Designation

PCC Nil

Serial number

Nil

Number of samples tested

One 22nd January 2014

Date(s) of Test(s) CPRI sample code no.

STDSST214S0089

Particulars of tests conducted Test in accordance with

Verification of the short circuit withstand strength As per clause 8.2.3 of IS: 8623 (Part I)-1993

Sampling plan

Not applicable

Customer's requirement

Nil

Deviations if any

Nil

Name of the Witnessing persons

Customer's representative

Shri Khatwa Kalpesh

Other than Customer's representatives

Nil

Test subcontracted with

address of the laboratory

None

Documents constituting this report (in words)

Number of sheets Five Number of oscillograms Two Number of graphs Nil

Number of photos Nil Number of Test circuit diagrams

Number of drawings

Two Two

(HIMANGSHU ROY) TEST ENGINEER



(ANUPAM AWASTHI) JOINT DIRECTOR

CENTRAL POWER RESEARCH INSTITUTE (MEMBER OF STL)



TEST REPORT

Test Report Number S2140065

Date: 27 FEB 2014

Summary of test

Test conducted

Verification of the short circuit withstand strength

Rating for which tested

65 kArms for 1.0 second with initial peak of 143 kA

Documents constituting this report

Oscillogram number

S2140065, S02, S04

Photograph numbers

Nil

Test circuit diagram number

OLTS/TCD-STC-01 & OLTS/TCD-STC-02

Drawing number

DWG/JECPL/CPRI/PCC/01 Sheet 1 of 2 DWG/JECPL/CPRI/PCC/01 Sheet 2 of 2

TEST ENGINEER

CENTRAL POWER RESEARCH INSTITUTE (MEMBER OF STL)





Test Report Number S2140065

Date: 27 FEB 2014

Ratings assigned by manufacturer

Test sample

LT Panel

Type

PCC

Designation

Nil

Serial number

Nil

Rated operational voltage

415 V

Rated current

4000 A

Rated insulation voltage

660 V

Rated frequency

50 Hz

Number of phases

Three phase + neutral

Rated short-time current

65 kArms for 1.0 second with initial peak of 143 kA

TEST ENGINEER